TM-CB4E-400-430WM-M
AC MOTOR FAN
EXT ROTOR.

DATASHEET-INSTALLATION GUIDE.

En-GB METRIC. M Series

TRANSMONK simply precise.



#### 1.0 Introduction

The specification describes the standards, operating environment, and technical requirements of the product.

- 2.0 Requirements of product standards and safety regulations
  - 2.1 Standards and requirements of the product followed
    - 2.1.1 GB12350 (Safety requirements of small power motors)
    - 2.1.2 EN60335-1 (Safety requirements of household and similar electrical appliances)
  - 2.2 The fan is CCC and CE approved.
  - 2.3 All materials are ROHS compliant
- 3.0 Mechanical requirements
  - 3.1 Motor magnetic materials

QZ-2 180 degree Celsius / High Strength enamelled wire QZ-2 180 degree Celsius

Stator and Rotor permeability magnetic material: Silicon Steel

Rotor: Die-Casting Aluminium

- 3.2 Balancing: The residual unbalance weight is less than the permit value of G6.3 (balancing precision grade, according to the standard of JB/T9101) when the fan is running at rated voltage and frequency.
- 3.3 Vibration: Vibration speed virtual value of fans accord with JB/T8689.
- 3.4 Lifespan: The fan is designed to run for a lifespan of 30,000~40,000 hours when the fan is running at rated voltage, rated load and maximum operating temperature.
- 4.0 Electrical Protection: The motor is equipped with the overload protection function, cut off temperature is between 150-160 degrees Celsius and reset temperature is between 90-120 degree Celsius

Leakage current: According to GB 12350

Installation mode: Horizontal & Vertical

Mode of speed regulation: Please provide the controller details with which you want to regulate the fan speed

5.0 Quality requirements

Quality requirements in accordance with ISO9001:2000 and inhouse quality standards

6.0 Operating and storing environmental requirements

Operating temperature range: -30 to +60 degree Celsius

Operating humidity range: 0% to 95% RH

Operating altitude: </= 1000 m

Ambient atmospheric pressure: 80-110 Kpa

Transportation/Storing temperatures range: -40 ~ +80 degree Celsius

Transportation/Storing humidity range: 0% ~ +75% RH

Packaging: Carton / Wooden packing

7.0 Standard of noise test: As per ISO 13347 (Determination of fan sound power levels under standardized laboratory conditions)

## **Product specification**

N	omina	IИ	ata
	OIIIIII	·	ulu

Fan model	model TM-CB4E-400-430WM		
Motor type	AC external rotor		
Power Supply	1~ 230 Volt		
Voltage range	207-253		
Frequency	50-60 Hz		
Input power	430 Watts		
Capacitor	12 Micro F		
Speed	1380 RPM		
Current	1.5 Amp		
Airflow@0 pa	4080 CMH		
Sound power	66 db		
Impeller type	Backward curve		

# Technical data

Protection class	IP54		
Thermal class	F(155 degree)		
Fan life*	~ 30,000 to 40,000 hours		
Weight	10 Kg		
Rotation direction	Clockwise, viewed toward rotor		
Certification	CE		
Impeller material	Metal		
Rotor	Die-casting Aluminium		
Bearing	Maintenance free ball bearing		


## **Product specification**

### Technical data


Installation mode Horizo	
Control method 1	TM controller
Control method 2	NA
Power output 1	NA
Power output 2	NA
Tach output	NA
Inbuilt protection	Thermal overload protection

<sup>\*</sup>If the fan is running continuously at rated voltage, rated load and maximum operating temperature

# Drawing (all dimensions are in mm)



### Performance curve




Curve 1: 50HZ Curve 2: 60HZ

# Data point table

Supply	RPM	Current (Amp)	Power (W)	Airflow (CMH)	Pressure (Pa)
(1) 1~230 V	1380	1.5	430	4080	0
(2)1~230 V	1550	2.5	600	4600	0

#### Connection terminal data



### **Important Note**

Cannot be used in coal mines where methane mixed gas and coal dust may cause explosion hazard.

Keep away from rotating parts when the fan is in running condition.

Cannot be placed and used in places where corrosive gas or steam is present.

Do not touch any of the high voltage line when the product is powered on.

The bearings used are ball bearings so please prevent the rotor from direct impact.

In order to avoid the circuit from breakdown OR insulation from damage, do not pull the wire harness while moving the product.

Customer fan unit should connect to ground well.

Do not touch the fan blade in running condition

Please use the fan under the conditions specified in this datasheet and contact us in case of any queries